

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 60142283

Blatt *Sheet*
0001

Ihr Zeichen *Client Reference*

Unser Zeichen *Our Reference*

Ausstellungsdatum

Date of Issue

0001--27143589 001

26.08.2019

(day/mo/yr)

Genehmigungsinhaber *License Holder*

ALTEZ ELK. AYD. SAN. TIC. LTD. ŞTİ.
MECİDİYE MAH. BEY SOK. NO:15
34930 SULTANBEYLİ İSTANBUL
Türkiye

Fertigungsstätte *Manufacturing Plant*

ALTEZ ELK. AYD. SAN. TIC. LTD. ŞTİ.
MECİDİYE MAH. BEY SOK. NO:15
34930 SULTANBEYLİ İSTANBUL
Türkiye

Prüfzeichen *Test Mark*



Geprüft nach *Tested acc. to*

IEC 61347-2-7:2011+A1
IEC 61347-1:2015+A1

Zertifiziertes Produkt (Geräteidentifikation)

Certified Product (Product Identification)

Lizenzentgelte - Einheit

License Fee - Unit

Build-in switching power supply Emergency Lighting LED Controlgear

Type Designation: ACKS 10

Trademark: ALTEZ
Rated Power: AC 220-240V; 50/60Hz;

Protection Class: Class II
Moisture Protection: IP20 ordinary
Ambient temperature (ta): 0°C... +40°C
Rated maximum temperature: (tc): 75°C
Mains supply current: 0.013A
Mains supply power: 3W
Output Voltage(Uout) : 3-200VDC
Output current(Iout) : 50mA
Battery nominal time: 3h

For EOF₁ ratings please refer to test report.

10

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com
Fax: +49 221 806-3935 http://www.tuv.com/safety

