



Ref. Certif. No.

DE 2-029358

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Luminaires for emergency lighting

Name and address of the applicant

ALTEZ ELK. AYD. SAN. TIC. LTD. ŞTİ.
MECİDİYE MAH. BEY SOK. NO:15
34930 İSTANBUL, Türkiye

Name and address of the manufacturer

ALTEZ ELK. AYD. SAN. TIC. LTD. ŞTİ.
MECİDİYE MAH. BEY SOK. NO:15
34930 İSTANBUL, Türkiye

Name and address of the factory

ALTEZ ELK. AYD. SAN. TIC. LTD. ŞTİ.
MECİDİYE MAH. BEY SOK. NO:15
34930 İSTANBUL, Türkiye

Ratings and principal characteristics

220-240V~; 50/60Hz; 1W; Ta: 0...45°C; Class II
a) IP40; b) IP65

Trademark (if any)

ALTEZ

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

a) AGCSO N1 DA; AGCSE N1 DA; b) ATA N1 DA

Additional information (if necessary may also be reported on page 2)

Refer to test report for model differences.

A sample of the product was tested and found to be in conformity with

IEC 60598-2-22:2014+A1
IEC 60598-1:2014+A1
See Test Report for National Differences

As shown in the Test Report Ref. No. which forms part of this Certificate

27147619 001

This CB Test Certificate is issued by the National Certification Body

**TÜVRheinland®**TÜV Rheinland LGA Products GmbH
Tillystr. 2, 90431 Nürnberg, Germany
Phone + 49 221 806-1371
Fax + 49 221 806-3935
Mail: cert-validity@de.tuv.com
Web : www.tuv.com

Date: 2020-11-06

Signature:

Ece Yücel EL Alawi